



# Bruhath Bangalore Mahanagara Palike


Deputy Health Office, Rajarajeshwari Nagara Zone,  
18th Main, Ideal Home Layout, Bangalore-98.

DHO/RRN/PR No./ 362 /22-23

Date : 16/03/2023

## Safe Drinking Water & Sanitary Certificate

This is to certify that inspected premises of Gurushree Education Society, No. 31/2&3, Doddabidarakallu Village, Nagasandra Post, Bangalore - 560073. (Ward No. 40-Doddabidarakallu) BBMP, under this we visited Gurushree Vidya Kendra on 16-03-2023. The accommodation is well ventilated & safe drinking water facilities for the students and members of staff of the institution. The premises and surrounding areas are clean and neat. There is sufficient numbers of was rooms for workers and staff, hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State Government.



*[Signature]*  
Deputy Health Officer  
Raja Rajeswarinagar Zone  
Bruhat Bangalore Mahanagara Palike  
16/3/23  
ಬಿ.ಎ.ಎ.ಎ.

To,  
Gurushree Vidya Kendra,  
No.31/2&3, Doddabidarakallu Village,  
Ward No. 40, BBMP,  
Nagasandra Post, Bangalore-560073.

Content of Seal Translated  
from Kannada to English.

Deputy Health officer  
Raja Rajeswarinagar Zone  
Bruhat Bangalore Mahanagara  
Palike.  
Bangalore *[Signature]*

*[Signature]*  
HEADMASTER/MISTRESS  
GURUSHREE VIDYA KENDRA  
Doddabidarakallu, Nagasandra Post  
BANGALORE - 560 073

D. SARALA KUMARI B.A. ...  
ADVOCATE & NOTARY PUBLIC  
GOVT OF INDIA  
391 EWS 14th B' CROSS  
Yelahanka, New Town  
BANGALORE - PF 560 064

GURUSHREE VIDYA KENDRA  
Doddabidarakallu, Nagasandra Post  
BANGALORE-560073.



# CHARITON RESEARCH INSTITUTE PRIVATE LIMITED

No.67/3, 1st Floor, Industrial Suburb, Yeshwanthpur, BANGALORE - 560 022. INDIA

## TEST CERTIFICATE

### WATER TEST REPORT

FORMAT NO: CRI/7.8/F/01

Name & Address of the Customer	M/s. Gurushree vidya kendra, Peenya industrial area, bangalore	Sample No: 168/ENV/05/2023
		Group: Water
		Product: Drinking Water
		Sample type: Drinking Water
Date of sample Collection	31.05.2023	Date of Completion: 02.06.2023
Date of Sample Receipt	31.05.2023	Date of Report: 02.06.2023
Duration of Test	31.05.2023-01.06.2023	Sample Condition: Good
Sampling Done by	CRI Representative	Env. Condition: Temp. 25°C & RH: 56%
Report number	C2/00007968	Sampling Method: IS 3025 Part 1

Sl. No.	Parameters	Units	Results	Limits as per IS 10500:2012		Test method
				Acceptable Limits	Permissible Limits	
1)	pH @ 25°C	---	6.37	6.5 - 8.5	No Relaxation	IS:3025(Part-11)
2)	Colour	Hazen	<1.0	5	15	5 of IS:3025(Part-4)
3)	Odour	--	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5)
4)	Conductivity	µS/cm	521	Not Specified	Not Specified	IS:3025(Part-14)
5)	Total dissolved solids	mg/l	128	500	2000	IS:3025(Part-16)
6)	Turbidity	NTU	<1.0	1	5	IS:3025(Part-10)
7)	Calcium as Ca	mg/l	12.8	75	200	5 of IS:3025(Part-40)
8)	Magnesium as Mg	mg/l	6.91	30	100	6 of IS:3025(Part-46)
9)	Chloride as Cl	mg/l	37.98	250	1000	2 of IS:3025(Part-32)
10)	Sulphate as SO4	mg/l	1.43	200	400	4 of IS:3025(Part-24)
11)	Iron as Fe	mg/l	0.04	1.0	No Relaxation	7 of IS-3025 (Part-53)
12)	Fluoride as F	mg/l	0.58	1	1.5	APHA 23 <sup>rd</sup> Edition 4500F D
13)	Nitrate as NO3	mg/l	1.28	45	No Relaxation	3 of IS:3025(Part-34)
14)	Alkalinity	mg/l	84	200	600	IS:3025(Part-23)
15)	Boron as B	mg/l	<0.01	0.5	1.0	6 of IS 3025(Part-57)
16)	Ammonia as NH3	mg/l	<0.01	0.5	No Relaxation	2.3 of IS 3025(Part-34)
17)	Hardness as CaCO3	mg/l	60	200	600	5 of IS:3025(Part-21)

*Kumar A*  
02/06/2023  
Authorized Signatory  
Dr Kumar A  
Technical Manager

Page 01 of 01

-----End of Report-----

*Saritha G.*  
GURUSHREE VIDYA KENDRA  
Doddabidarakallu, Nagasandra Post.  
BANGALORE-560073.

*[Signature]*  
HEADMASTER/MISTRESS  
GURUSHREE VIDYA KENDRA  
Doddabidarakallu, Nagasandra Post  
BANGALORE - 560 073



Terms & Condition Over Leaf

Tel.:080-23479296 Fax : 23479721 Mob : 9448000637 / 9845015964  
E-mail : info@charitonindia.com / marketing@charitonindia.com Web : www.charitonindia.com  
CIN: U73200KA2020PTC134050 GST NO: 29AAICC7110N1ZC